

STATE OF NEW HAMPSHIRE
DEPARTMENT OF ADMINISTRATIVE SERVICES
BUREAU OF PURCHASE AND PROPERTY
STATE HOUSE ANNEX - ROOM 102
25 CAPITOL ST
CONCORD NH 03301-6398

DATE: 6/21/2004

ADDENDUMS TO BID #462,463 AND #464 generator and transfer switch

ADDENDUM # 1

DATE OF BID OPENING: #464 - 6/24/2004	TIME OF BID OPENING: 1:30 PM
#463 - 6/24/2004	TIME OF BID OPENING: 1:45 PM
#462 - 6/24/2004	TIME OF BID OPENING: 2:00 PM

SPECIFICATION - ADDITIONAL BIDDER INFORMATION & REQUIREMENTS:

Hillsborough Bid #462:

Item 01: Patching of pavement will be by owner.

Item 02: Generator pads meeting manufacturers recommendations are acceptable.
Precast pads are acceptable if they meet manufacturers recommendations.

Item 03: The 90 Ampere breaker feeding the Salt Shed (miss-labeled as Pumps) shall be replaced with a 2P 30A breaker.

N.Haverhill Bid #463:

Item 01: Generator pads meeting manufacturers recommendations are acceptable.
Precast pads are acceptable if they meet manufacturers recommendations.

Wentworth Bid #464:

Item 01: Generator pads meeting manufacturers recommendations are acceptable.
Precast pads are acceptable if they meet manufacturers recommendations.

**PLEASE UTILIZE THE APPROPRIATE INFORMATION TO THE PARTICULAR BID YOU ARE
MAKING AN OFFER FOR**

NOTE: IN THE EVENT THAT YOUR BID HAS BEEN SENT TO THIS OFFICE PRIOR TO
RECEIVING THIS ADDENDUM, RETURN ADDENDUM WITHIN THE SPECIFIED TIME
WITH ANY CHANGES YOU WISH TO MAKE AND MARK ON THE REMITTANCE
ENVELOPE BID NUMBER AND OPENING DATE. RETURNED ADDENDUM WILL
SUPERSEDE ANY PREVIOUSLY SUBMITTED BIDS.

BIDDER: _____
PLEASE TYPE OR PRINT NAME

ADDRESS: _____

BY: _____
THIS BID MUST BE SIGNED

ZIP _____
TEL.# _____

PURCHASING AGENT: MICHAEL P. WALSH II
TEL#:(603) 271-3235
FAX#:(603) 271-2700